



太阳能产品认证证书

证书编号：CQC19024234322

申请人名称及地址

宁波尚唯斯智能科技有限公司
浙江省宁波（慈溪）绿色农产品加工基地绿园二路1号

制造商名称及地址

宁波尚唯斯智能科技有限公司
浙江省宁波（慈溪）绿色农产品加工基地绿园二路1号

生产企业名称及地址

宁波尚唯斯智能科技有限公司(V036946)
浙江省慈溪市崇寿镇绿色园区绿园二路1号

产品名称和系列、规格、型号

光伏并网逆变器
STT-25KTL-CN, STT-20KTL-CN, STT-17KTL-CN (见附件)

产品标准和技术要求

NB/T32004-2018

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC33-461239-2018 认证规则的要求，特发此证。

发证日期：2019年12月16日

本证书的有效性依据发证机构的定期监督获得保持。



主任：_____

陆梅



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

T 0012352



SOLAR PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC19024234322

NAME AND ADDRESS OF THE APPLICANT

Ningbo Sunways technologies Co.,Ltd
No. 1 Luyuan 2nd Road, ECO-Product Processing District, Ningbo (Cixi), Zhejiang Province

NAME AND ADDRESS OF THE MANUFACTURER

Ningbo Sunways technologies Co.,Ltd
No. 1 Luyuan 2nd Road, ECO-Product Processing District, Ningbo (Cixi), Zhejiang Province

NAME AND ADDRESS OF THE FACTORY

Sunways technologies (Ningbo) Co.,Ltd (V036946)
No. 1, Luyuan Road, Green Industrial Zone, Cixi, Ningbo, Zhejiang Province

PRODUCT NAME, MODEL AND SPECIFICATION

GRID-CONNECTED PV INVERTER
STT-25KTL-CN, STT-20KTL-CN, STT-17KTL-CN (See Appendix)

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

NB/T32004-2018

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection
This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC33-461239-2018 .

Valid from: Dec.16,2019

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.



President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

T 0012352



太阳能产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC19024234322

纸 号: 12352

STT-25KTL-CN

直流输入: MPPT 电压范围200V-950Vdc, 最大直流输入电压1100Vdc, 最大输入电流22A+22A;
交流输出: ~230V/400V, 50Hz, MAX. 39A, 额定交流输出功率25kW;

STT-20KTL-CN

直流输入: MPPT 电压范围200V-950Vdc, 最大直流输入电压1100Vdc, 最大输入电流22A+22A;
交流输出: ~230V/400V, 50Hz, MAX. 31.9A, 额定交流输出功率20kW;

STT-17KTL-CN

直流输入: MPPT 电压范围200V-950Vdc, 最大直流输入电压1100Vdc, 最大输入电流22A+22A;
交流输出: ~230V/400V, 50Hz, MAX. 28.4A, 额定交流输出功率17kW.

注: 此附录与证书同时使用时有效。



主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>